

LASERMET SOUNDER

INSTRUCTION MANUAL

SIL SERIES AUDIBLE WARNING DEVICE

Issue 2



LASERMET Sounder Instruction Manual

Contents

1	Safe	ety Warnings	3		
2	Con	cept	4		
	2.1	Intended Use	5		
	2.2	Features	6		
	2.3	Qualification	6		
	2.4	Evaluation	6		
3	Оре	eration	11		
	3.1	Time Dependencies	12		
	3.2	Function Test	13		
	3.3	Process Safety Time	13		
	3.4	Proof Test	13		
4	Inst	allation	15		
	4.1	Limits of Use	15		
	4.2	Requirements for the Installation and Putting into Service	15		
5	Wir	ing	17		
6	Tro	ubleshooting	19		
	6.1	Maintenance	19		
	6.2	Disposal			
7	Spe	cifications	20		
	7.1	Safety Specifications	20		
	7.2	Technical Data	20		
	7.3	Tone Selection Table	22		
8	Warranty24				
9	Con	tact Details	25		



1 Safety Warnings

This device is intended to be used as part of a safety system which may be used to protect personnel and equipment from possible injury, damage, or loss.

As such it must be installed and wired according to these instructions and tested by suitably qualified persons. No attempt may be made to tamper with the parts, open them, or use them outside of the parameters contained herein.

The units are only designed to be fixed to surfaces using their inbuilt fixing holes. They must not come into contact with each other or any other moving part when in use. The parts should never be subject to impact or mechanical strain.

Safety switches should never be defeated or bypassed. It is imperative that all steps are taken to ensure that any spare actuators are made unavailable, such that they cannot be used to defeat the switch or reduce the protection offered by the system in any way.



2 Concept

The sounders of the DS-SIL series are audible warnings for the signalling of dangerous situations in safety relevant applications, e.g. as an intrinsic part of an E/E/PE system (according to EN61508).



Figure 1. Overview

The sounders are for constructed for the robust requirements in industrial circumstances and can reach a sound level of up to max. 114 dB(A). The sounders suited to indoor and outdoor use create a warning signal in 30 different tones which can be selected with the help of an internal DIP switch. There is also the possibility of (optionally) switching to three other tones with external control. Next to these factory settings, the combination of tones can be freely arranged by on-site programming. The function of the sounder is internally monitored electrically and acoustically by a diagnosis channel. If an acoustic warning signal is made, then an MOS relay is conductive. This information can be interpreted with a superior control.





Figure 2. Illustration of the functionality of the switching parts of the sounder with monitoring

Lasermet provides a full range of laser interlock equipment including control systems, interlock switches, illuminated warning signs, laser shutters, door locks, external power supplies etc. which can be connected to provide a complete laser interlock system. Full support, design and installation is available from Lasermet, please contact us for any queries. Contact details are given at the end of this manual.

2.1 Intended Use

With a danger and risk analysis, dangers created in the installation can be ascertained. If a dangerous situation is to be avoided, then the sounders can be used as an integral part of a technical safety system (Safety Instrument System - SIS) up to safety integration level 2 (SIL 2).

Because of the very different integration of the sounders in various safety architectures, they must be viewed differently. The following uses are described in the safety manual:

- Use as a starting alarm of machines or similar applications
- Use as a warning system without automatic test function via a superior control
- Use as a warning system with automatic test function via a superior control

In general, the operational safety of the device and the therefore connected system is only guaranteed during intended use in accordance with the specifications of the operating manual. Custom-designed dangers could result from inappropriate or unintended use of this device.



2.2 Features

The sounder described alone does not perform any protective function (partial system) but is concepted for installation as an output device with diagnosis (output) in the loop of a protective function (SIF). The system (see Fig. 1 and Fig. 2) only ever shows a partial system of a technical safety system (SIS). It should be observed through the system integrator that the entire 'loop', according to the use, has to meet the required safety integration level (SIL). The system integrator must establish all measures in order to reach or maintain the safe condition in the SIS in the case of a fault.

The diagnosis system of the device diagnoses the acoustic warning signals of the failed release and function upon request and reports this via an alarm relay to a superior control system.

This does not constitute an online diagnosis within the meaning of IEC61508 and, without further measures, has no influence on the intermediary values PFH, PFD, SFF and HFT. The diagnosis can only be used for the following uses/architectures:

- Systems with small requirement rate of the safety function (low demand) which are regularly subject to a test release. If the regular test is automated, then it can be evaluated so that the diagnosis coverage flows into the calculation of the reliability data.
- Systems in which the safety function can be tested before the existence of the dangerous condition, such as starting alarms of machines, for example.

2.3 Qualification

Handling according to this operating manual and safety manual can only be carried out by trained electrical technical personnel authorised by the plant operator.

The integration of this sounder in an application is to be carried out according to the rules of the functional safety according to IEC 61508/IEC 61511.

Proof tests and their proof can only be carried out by authorised electrical technical personnel.

2.4 Evaluation

Use as a Starting Alarm of Machines

For use as a starting alarm of machines, the function of the generation of the acoustic warning signal in the sounder channel is to be assessed as a function of the machine. The safe condition is reached when the acoustic warning system works reliably. The diagnosis channel monitors this function and, upon failure, leads in the safe condition via a safety loop. This architecture is illustrated schematically in Fig. 3.

- a) The machine control activates the generation of the acoustic warning signal
- b) The diagnosis monitors the acoustic function of the sounder channel and reports to a safety relay, for example, as soon as it is available
- c) The machine control only starts after the okay report of the machine



In this architecture, only the diagnosis channel is assessed according to IEC61508. The safety loop is made up of diagnosis channel with recording, evaluation of the dangerous condition and elements of the machine control for the reaching of the safe condition. The latter was not taken into account in the analysis.



Starting alarms and similar uses are architectures that can normally be attributed to the 'high demand mode'. The acoustic function must be tested immediately before switching on the machine or before entering the dangerous condition.

Safety Para	meters for Starting	Alarms	
T _{ProofTest}	5	10	Years
PFD _{mean}	1.68 x 10 ⁻³	3.36 x 10⁻³	(1 / requirement)
PFH	7.7 x 10 ⁻⁸	7.7 x 10⁻ ⁸	(1 / h)
SFF	98.	.98	%
DC	()	%
MTTR	4	8	h
λ_{DU} diagnosis switch	76	5.5	Fit
λ_s Complete	7456		Fit
HFT	()	
Suitability of the system for use in safety chains until	SIL	. 2	

Use as an Acoustic Warning System in One-channel Version

The function of the acoustic warning system is to be assessed as a safety function in the use as a warning system after recording dangerous conditions. A measurement records a dangerous condition and introduces the safe condition by controlling the acoustic warning system (personnel/operator is warned).

Note: The warning of people is a voluntary measure as it requires willing handling of one or more people.



This architecture only corresponds to the requirements of the European Machinery Directive if, according to state-of-the-art technology, no constructive safety or other voluntary measure is possible to reach a safe condition.

The diagnosis can only be taken into account if there is regular, automated function checking, the minimum interval of which must be in accordance with approx. ten to one hundred times the requirement rate according to IEC/EN61508. This possibility is only available in low demand mode and is further described and evaluated later in this manual.

The acoustic warning system with diagnosis function is implemented as follows:

- a) A measurement (input (1), logic (2)) records a dangerous condition and activates the acoustic warning system (output (3))
- b) The diagnosis (4) monitors the function of the acoustic warning system and reports OK to a superior control system (5)
- c) If an OK message takes place, then the superior control system (5) introduces the safe condition via other measures (6).



The sounder partial systems (output - position 3) and diagnosis channel (diagnosis - position 4) are evaluated. It should be noted that the sum of all PFH or PFD values must correspond to the required safety integration level for the entire system.



Use as an Acoustic Warning System without Test Function

The safety function – generating a warning signal – is realised via a one-channel system (1001 according to IEC/EN61508) without taking account of the diagnosis function, as also described in the Features section of this manual.

The low and high demand mode is useable in the system without the automatic test function.

Evaluation for applications with high requirement rate or continuous requirement (high demand) and low requirement rate (low demand) without automatic test release of the monitoring equipment.

TproofTest	1	4	Years
PFD _{mean}	1,1 x 10-3	4,4 x 10-3	(1 / requirement)
PFH	2,5 x 10-7	2,4 x 10-7	(1 / h)
SFF	96,8	96,8	%
DC	0	0	%
MTTR	4	8	h
λ_{DU} Complete	25	51	Fit
λ _s Complete	7535		Fit
HFT	0		
Suitability of the system for use in safety chains until	SII	2	

The monitoring of the function of the sounder is used during the 'proof test'. The 'proof test' is described in the Proof Test section of the manual.



Use as an Acoustic Warning System with Test Function

This monitoring can only be used with systems in low demand mode. The test function, as described in the Function Test section, is taken into account. This must be automated and must take place at least ten to one hundred times more often than the expected requirement rate. The system with test function, including the diagnosis and respective measures in the fault message, must be in accordance with the requirements of the function safety according to IEC/EN61508.

In the following, a requirement rate less frequent than once a year is assumed (low demand).

Daily test interval (24h)	PFD _{mean}	3.0 x 10 ⁻⁴	(1/requirement)
T _{ProofTest} = 1 year	SFF	90.5%	%
MTTR = 48 h	DC	73%	%
Weekly test interval (168h)	PFD _{mean}	3.1 x 10 ⁻⁴	(1/requirement)
T _{ProofTest} = 1 year	SFF	90%	%
MTTR = 48 h	DC	72%	%
Monthly test interval (672h)	PFD _{mean}	3.6 x 10 ⁻⁴	(1/requirement)
T _{ProofTest} = 1 year	SFF	88.6%	%
MTTR = 48 h	DC	67%	%
Monthly test interval (672h)	PFD _{mean}	4.5 x 10 ⁻³	(1/requirement)
T _{ProofTest} = 15 years	SFF	90.5%	%
MTTR = 48 h	DC	73%	%
λ_{DU} Complete	251	Fit	
λ_s Complete	7535	Fit	
HFT	0		
Suitability of the system for use in	SIL 2		



3 Operation

For the evaluation of the monitoring a superior control system, which is in accordance with the functional safety requirements of IEC/EN61508, must be available. The control system must be capable of carrying out a fault analysis according to the capacity of failure in connection with the operational condition of the sounder. The following dependencies between operational condition and capacity of failure are therefore possible. Please also take note of the possible switching status as shown in Fig. 5 and Fig. 6.

It is assumed that the monitoring equipment is supplied with operational voltage at least 1s before switching the sounder channel on and the condition of the alarm output is checked 0.5s after switching on at the earliest. This procedure is an integral part of the automatic test function.

- a) Switching on the power supply of the sounder channel in a fault free condition results in the controlling of the MOS relay (the output of the MOS relay is low resistance). This takes place with a delay of 0.2 seconds. This is on the condition that a tone has been selected with help of the DIP switch for the tone selection or a respective tone has been activated from the 'external tone selection' and the monitoring circuit is attached to the power supply. If the capacity of failure has not become low resistance after this time then a fault has occurred in the supply of the sounder channel, in the sounder channel itself or in the monitoring equipment. If the capacity of failure is already low resistance beforehand, then there is a conductor end or a malfunction in the monitoring circuit.
- b) If the operational voltage of the sounder channel is switched off, a fault message is given via the fault alarm relay with a delay of 0.2s to 2.5s. With an uninterrupted sounding, a reaction of the alarm relay of >0.2s can be expected. The longer delay can result in tonal pauses in uninterrupted sounding when switching off.
- c) If tones are automatically ended by the sounder (such as with tones 26 and 98, for example) then a fault is also reported after 4s. In this case, the control must take into account the procedure of the tonal generation (60s) and reset it.
- d) If, during operation of the sounder channel, it is the case that the sounder remains off without the operational voltage for the sounder channel being switched, the alarm output becomes high resistance after a maximum delay of 4s and therefore a fault is reported.
- e) The minimum duration of an alarm is 5s. Only after this time has lapsed does it switch back to the normal monitoring mode.



3.1 Time Dependencies



Figure 5. Function Time Diagram



Figure 6. Function Time Diagram with Fault



3.2 Function Test

For applications in 'low demand mode' with safety requirements an automatic function test should be carried out with regular intervals. The test intervals can be seen in the 'Use as acoustic warning system with test function' section.

Both part systems, the sounder channel and the monitoring circuit, have separate power supply connections. This means that a check of the function is possible and can be carried out as follows (time dependencies see Fig. 5 and Fig. 6).

- a) Switching on the monitoring power supply when the sounder channel is not activated, (can be omitted depending on use if the monitoring is continuously connected to the supply)
- b) Check whether the fault alarm relay has high resistance >0.5s after switching on,
- c) Switching on the sounder channel (sound is generated)
- d) Check whether the fault alarm relay has switched after >0.2s (low resistance)
- e) Switching off the operational voltage of the sounder channel, the fault alarm relay must have fallen away (high resistance) after 2.5s at the latest
- f) Switching off the monitoring (depending on use)

It is important for the system test that the change of the switch position of the alarm relay is detected depending on the generation of the acoustic warning signal. With which distances a system test has to take place is dependent on the eventual use in which the sounder is involved. The equipment specific check intervals must be defined in the respective proof of safety.

The function test can be shortened if a tone without interrupted tones is used. Then time in point e) can be reduced to 0.3s. It is required that a tone is selected at the DIP switch of the sounder or a tone is activated simultaneously with the sounder from the 'external tone selection' option.

3.3 Process Safety Time

Conclusions for the required process safety time can be drawn depending on use according to the function time diagrams. The reaction times for the generation of the acoustic warning signal and the switching status of the alarm relay depending on the switching on and off time of the operational voltage (Fig. 5) and in the case of a fault (despite demand, the warning signal is not generated, Fig. 6) are illustrated here.

With the connection of the operational voltage, the sounder generates an acoustic warning signal after 0.3s at the latest and reports this via the alarm relay (output low resistance). This means the 'generation of a warning signal' safety function has been activated. Further explanations of the reaction times of the alarm relay can be found in the Operation section.

3.4 Proof Test

Manual checks of the safety function and the visual condition of the sounder are to be performed in regular intervals. This test serves to identify dangerous faults that are not automatically detected and the general condition of the device. If the proof test is not carried out in the required, defined, timely intervals this leads to the loss of the reachable SIL evaluation.



The sequence of the carrying out of the individual test steps of the proof test is arbitrary. The 'proof test' is to be carried out as follows:

Test	Test Step	Test Instructions
Visual Check	a.) Housing	mechanical damage, corrosion damage, attachment to the location
	b.) Horn Outlet	not covered or locked
	c.) Cable Screw Joint	tight fit, seal for the cable guaranteed
Electronic Function	d.) Manual Function Test	 manual, step-by-step deployment of the individual test steps as described in the Function Test section under use of one of the following tones: 88, 90, 92, 100, 108, 112, 116, 117 (Important – interrupted sound with intervals >0.5s!, recommended tone no. 117), adjust respective tone with DIP switch Check of the respective switching status of the alarm relay of the monitoring circuit with check of the specified max. switching times (< 0.2s sound on, < 2.5s sound off, see also Fig. 5) acoustic check whether a sound is generated upon request
	e.) Electrical Isolation	Check the isolation between the alarm relay output and connection of the operational voltage supply of the monitoring channel. Also, the connections to X3 should be disconnected. The connection X3 contact 3(4) to contact 5(6) is to be checked with a current flow check. This must be high resistance (>1M Ω).
Acoustic Function	f.) Tone	Acoustic check of the tone pattern of the locally used tone. This can take place subjectively by trained personnel. The pattern (intervals, frequency response curve, frequency change, interval times) is to be checked as shown in the tone table in the Acoustic Data specifications section. The person must be capable of identifying the warning signal. Alternatively, technical implements suitable for this test can be used. The signal can be taken oscillographically for analysis with a microphone and preamplifier or electronically from PIN13 of the integrated switch U4 (earth connection to the heat sink of the U3 switching circuit, TTL level).
	g.) Tone Option TAS	The test step 'f.) Tone' must be repeated for every additionally activated tone in the application when using the 'external tone selection' option.
	h.) Noise Level Check	Noise level measurement or subjective assessment of the noise level by a representative group of people during a test release under max. ambient noise level. The noise level must be more than +10dB above the max. ambient noise level or be clearly recognizable by this group of people. The tone in the system is to be used. Alternatively, a noise level measurement can be taken in an anechoic room or under open-air conditions. In this case, for tone no. 57, a noise level of at least the rated sound level - 3dB(A) must be reached with a meter distance.
Logging	i.) Log of the Test Results	must comply with the rules for functional safety according to IEC/EN61508



4 Installation

The adjustment of the hardware is restricted to the choice of the tone on DIP switch S1. The tone and related DIP switch generation is taken from the tone table in the Acoustic Data specifications section. The position and assignment of the DIP switch are illustrated in the Wiring section.

The combination of tones – this is only relevant for versions with external tone selection – can be adjusted. The programming for tone 32 is described in the Acoustic Data specification section.

4.1 Limits of Use

The limits that can be taken from the technical data are to be kept.

The limits for the calculation of the safety integrity of the sounder in systems is to be taken from the Evaluation section.

Changes to the sounder are only possible via the manufacturer. The safety parameters must be recalculated, and the functional safety must be tested. Changes by the user are not allowed and lead to voiding of the warranty.

4.2 Requirements for the Installation and Putting into Service

- a) The sounder corresponds to state-of-the-art technology and was constructed taking into account the specific regulations and guidelines.
- b) The operating manual and the safety manual are aimed at educated and authorised electrical technical personnel. Their contents must be made available to the technical personnel and implemented.
- c) The electrical connection can only be carried out by persons authorised for this. Before connecting it is to be ensured that the sounder is not live.
- d) The safety instructions of this operating manual, the local installation standards as well as the valid safety regulations and accident prevention guidelines are to be observed.
- e) The sounder must be selected so that a clear perceptibility of the acoustic signal at maximum ambient noise level can be guaranteed. The warning signal must exceed the ambient noise level by +10dB(A).
- f) When using numerous signals (tones), they must be clearly distinct in order to enable specific actions by trained personnel.
- g) Do not install two warning devices directly next to one another as mutual influencing during simultaneous operation cannot be ruled out. A distance of >1m fulfils the requirement.



- h) The front part can be removed by releasing the 4 screws on the front side. Ensure a clean and undamaged seal during the installation.
- i) The connection assignment is illustrated in the Wiring section.
- j) The cable screw joints with which the device is equipped are intended for round cable crosssections and an outer diameter of 8mm to 12mm. This guarantees the seal effect of the cable screw joint. If cables with other diameters or shapes are to be used, then other suitable cable screw joints must be used. The IP protection category IP67 cannot be impaired.
- k) During installation make sure that the cable(s) is/are secured against pulling and twisting. Please note: the devices are not intended for mobile use.
- I) The opening of the horn is not to be facing upwards, particular when in use outside or in a dusty area.
- m) The tones are set with help of the DIP switch S1, see tone table in the specifications section.
- n) The housing screw plugs (Torx-T20) of the sounder part are to be tightened with a torque of approx. 2 2.5 Nm for at least two cycles when closing the housing.
- o) The correct function of the sounder is to be checked when newly commissioned, recommissioned and after every repair. The safety function in particular is to be validated. The function test as described in the Function Test section is also to be carried out.
- p) Before repair, the supply voltage on the type plate is to be checked. The wrong operational voltage can lead to damages or to the destruction of the equipment.
- q) The sounder can only be operated in an undamaged and operationally safe condition within the specific data.
- r) The operator is responsible for the trouble-free operation of the device.



5 Wiring

CAUTION: Danger of electric shock!

Before all work on equipment, the following should be observed: switch off the equipment before opening. All work on the equipment is only to be carried out by authorised technical personnel.

WARNING: Detriment to hearing!

In order to avoid a detriment to hearing, when working directly next to the sounder, ear protection is to be worn.



The sounders are provided with a reverse polarity protection. No function when polarity is reversed! Figure 7. Connection assignment and control elements

Terminal connections X1

1	2	PE
3	4	+ 24V DC sounder operational voltage
5	6	- 0V DC sounder operational voltage

Terminal connections X3		1	2	+ 24V DC monitoring channel operational voltage
		3	4	- 0V DC monitoring channel operational voltage
	\ر	5	6	Potential-free alarm contact (IN) , MOS-Relay, 230V~/ 80mA
	L	7	8	Potential-free alarm contact (OUT) , MOS-Relay, 230V~/ 80mA



External Tone Selection via Control Voltage – short term -TAS



		Ub	S2	S3
Stage	1	х		
Stage	2	Х	х	
Stage	3	Х		х
Stage	4	Х	х	х
	x = clo	sed		

Figure 8. Optional connection assignment TAS

Terminal connect	ctions	
X2	1	+ 24V DC Control voltage Tone Stage 2
(Option external	2	+ 24V DC Control voltage Tone Stage 2
Tone selection	3	+ 24V DC Control voltage Tone Stage 3
–TAS)	4	+ 24V DC Control voltage Tone Stage 3

Electricity and voltage limiting measures must be implemented in the superior system for the supply as well as for the fault report interface.



6 Troubleshooting

Despite high functional safety, faults can occur during use. These can have consequences in the sounder, in the operational voltage supply or in the evaluation in the control system.

It is the responsibility of the plant operator to take suitable measures to deal with occurred faults.

The first measure can be to check the operational voltage, check whether an acoustic warning signal is generated and check the position of the alarm relay contacts, depending on the operational condition of the sounder. The cause of the fault can thereby be traced. A step-by-step function test as described in the Function Test section and carried out during the 'proof test' in the Proof Test section can also help a lot.

If the sounder is defective, it should be repaired in the production plant. Only original replacement parts can be used as replacements.

Faults that affect the functional safety are to be reported to the supplier.

6.1 Maintenance

The sounder does not require any special maintenance. However, the 'proof test' interval should be observed.

Changes, modifications, faulty and incorrect use as well as not observing the advice of this operating manual void the warranty.

External cleaning should be done with weak soapy water without use of solvents.

6.2 Disposal

Recycling of the device can be carried out by specialist operations. The electronics can therefore be easily removed from the housing. The housing material is made from aluminium die casting and the magnet from ferromagnetic material.

Should you not have an opportunity to dispose of the old device correctly, please speak to us about returns and disposal.

The device at hand is not subject to the WEEE guideline 2002/96/EC and the respective national laws. The device is only to be sent to a specialist recycling operation and not to be disposed at communal collection points.



7 Specifications

7.1 Safety Specifications

- IEC61508 Functional safety of electrical/ electronic/ programmable electronic safety-related systems
- IEC61511 Functional safety – safety instrumented systems for the process industry sector
- EN ISO 13849-1 (following) Safety-related parts of control systems

With the identification of the device with the CE sign, the supplier confirms the fulfilment of the legal requirements of the applicable EC guidelines.

The DS-SIL sounder fulfils the requirements of the functional safety according to IEC 61508/IEC 61511.

7.2 Technical Data

Dimensions



Dimensions are approximate. Values given as 'typical' are average values measured across a number of samples and are not guaranteed. Lasermet reserve the right to alter any specification without prior notice.



Electrical Data

	DS10	DS5	
Nominal Voltage	24 V DC	24 V DC	
Voltage Range	19 V - 29 V	19 V - 29 V	
Current Consumption	0.42 A	0.28A	
Current Consumption monitoring circuit	20mA		
Control Current option TAS	< 5mA (24V-)		
	Solid sta	te relay	
Capacity of failure contact	max. 230V~ / 80mA		
	RDSON < 35Ω		
Duty Cycle	100 %		
Lifatima	A replacement of the device is recommended after		
	20 years or 2500 operating hours.		

Mechanical Data

Degree of Protection	IP 66 / 67 (EN 60529)	
Protection Class	I	
Mounting Position	Opening of bell mouth shall not point upwards	
Cable Entry	2x M20x1,5	
Clamp Range of cable gland	8 – 12 mm	
Torminals	Cage Clamp 0,08-2,5mm ² (AWG28-12),	
	(AWG12 THHN, THWN)	
Weight	1,95 Kg	
Material of Housing	Al- die cast GD-Al Si12 Cu	
Surface Coating	Anodized, Polyester resin varnish, RAL 3000 - flame	
	red	

Climatic Data

Operating Temperature	- 25 °C to + 55 °C
Storage Temperature	- 40 °C to + 70°C
Relative Humidity	90%
Applicability for outdoor use	suitable for outdoor use

Acoustic Data

	DS10-SIL	DS5-SIL
Maximum Sound Level	114 dB(A) / 1m	108 dB(A) / 1m
Sound Patterns	30)



Sound Level





7.3 Tone Selection Table

ge 1	DIP-Switch								Option TAS see chapter 4.13		
basic tone sta	1	2	3	4	5	6	Description basic tone stage 1 (stage no. 2 = pre-set)		Stufe 2 stage 2	Stufe 3 stage 3	Stufe 4 stage 4
0		1					No tone		2	88	57
2					ON		Unified emergency signal/ - DIN 33404/T3 -	1200Hz 500Hz	128	112	57
15	ON		ON	ON			Tone not suitable for use with monitoring circuit! Sawtooth	3s 1200Hz 0.5s	131	54	112
23	ON		ON	ON	ON		Siren	500Hz 2400Hz	24	60	112
24	ON	ON		ON	ON		Siren	300Hz 1200Hz	55	23	131
26	ON	ON	ON		ON		Siren	405 1000Hz 109 150Hz	2	100	93
31	ON	ON	ON	ON	ON		Siren - NF C 48-265 -	0,5s 1600Hz 1400Hz	128	54	57
32						ON	Selection of the freely assignable tone combinations in stag	es 2, 3 and 4. For prog	Iramming	g see be	low
36	ON	ON	ON				Siren	1500Hz 38 700Hz	146	67	57
45			ON	ON			Siren	1200Hz 38 38 500Hz	2	57	93
54		ON	ON	ON	0		Continuous tone	1500 Hz	2	57	67
55		ON	ON		ON		Continuous tone	1200 Hz	2	88	128
57			ON				Continuous tone	950 Hz	2	128	88
60		ON	ON				Continuous tone	825 Hz	24	93	125
63		ON		ON	ON		Continuous tone	725 Hz	2	97	93
67		ON		ON	1		Continuous tone	500 Hz	24	93	125
88			ON		ON		Interrupted tone	950Hz	2	57	128



							•	Local Contraction of the second second			
90	ON		Γ	Γ		Γ	Interrupted tone	0.5s 0.5s 825Hz	2	127	108
92	ON			ON			Interrupted tone	0.25s	131	146	57
93		ON			ON		Electromechanical horn	800Hz	2	128	57
97	ON				ON		Interrupted tone	0.7s 0.3s 725Hz	2	63	93
98		ON					Swedish imminent danger signal - SS 031711 -	0.125s 0.125s 700Hz	112	128	57
100	ON	ON	ON	ON			Interrupted tone	0,875s 0,875s 0,875s	2	57	125
108		ON	ON	ON	ON		Interrupted tone	0.5s 0.5s 500Hz	2	127	60
112				ON			Audible emergency evacuation signal - ISO 8201 -	15 950Hz	2	57	128
116	ON		ON		ON		Interrupted tone Abandon ship	+ ^{1s} + ^{1s} 950Hz	117	93	125
117	ON		ON				Interrupted tone (IMO SOLAS III/50 + SOLAS III/6.4)	2,5s	93	116	125
125	ON	NC		ON			Alternating tone	20ms 20ms	57	93	24
127	ON	ON					Alternating tone	0.5s 0.5s	2	90	60
128				ON	ON		Alternating tone	1025Hz 825Hz	2	112	57
131	ON			ON	ON		Alternating tone	0,25s 0,25s 800Hz	24	55	23
142	ON	NC			ON		Alternating tone	0.25s 0.25s 900Hz 0.25s 0.25s	2	54	88
146			ON	ON	ON		French Fire sound / NFS32-001 -	0.45 0.15 554Hz 440Hz	128	67	4

Individual combination of the tones for stages 1, 2, 3 and 4 (tone 32 of the Tone Selection Table)

In the case of sounders with external tone selection, the combinations of the tones for the stages 1 to 4 can be altered and thus adapted to the particular application. The tone of stage 1 will continue to be activated with selector switches 1 - 5. Stages 2, 3 and 4 are programmable.

Programming

The programming of stages 2, 3 and 4 can be described as follows:

- De-energise sounders
- Change to programming mode by selector switch position 7 to ON
- Selection of the selected (basic) tone by appropriate selector switch settings 1 5. (see sound selection table, basic tone stage)
- Brief application of service voltage and control voltage to the appropriate input terminals for stages 2, 3 or 4 (see also connection examples, 4.13)



The basic tone set is taken over by the stage activated.

WARNING: When the service voltage is switched on do not touch any live parts of the sounder.

- Repeat for all stages (2 4) which are to be activated.
- De-energise sounders
- Switch off programming mode by means of selector switch setting 7 to OFF.

The tone for stage 1 is set, after the programming mode has been left, with the help of selector switches 1 to 5.

Selection of the individual tone combination, by setting the selector switch 6 to ON (see Tone Selection Table, Tone Selection 32)

8 Warranty

Lasermet provide a 12-month warranty for defects in materials and manufacture, from the date of installation or delivery. Installations completed by Lasermet are covered against defects in workmanship for 12 months.

Damage or defects caused by other factors are not covered. For example, industrial contamination, incorrect cleaning, storm damage. Consequential loss is not covered under warranty. Compensation for indirect or direct loss or damage is expressly excluded. Rectification of the defects or a replacement does not initiate a new warranty period.

For all deliveries, payments and other legal transactions, English law takes precedence for any litigation.



9 Contact Details

Lasermet provide a full range of laser interlock equipment including interlock switches, illuminated warning signs, laser shutters, entry keypads with built-in fail-safe override timer, door locks, external power supplies etc. which can be interconnected to provide a complete system. We also supply equipment and consultancy covering all aspects of laser safety. Full support, design, and installation is available from Lasermet, please contact us for any queries.

For sales and technical support:

Lasermet Ltd. Lasermet House, 137 Hankinson Road, Bournemouth BH9 1HR United Kingdom.

Tel: +44 (0) 1202 770740 Fax: +44 (0) 1202 770730

Email: sales@lasermet.com Website: www.lasermet.com

Lasermet Inc.

10N Martingale Road, Suite 400, Schaumburg, Illinois 60173 United States.

Tel: 847 466 1475

Email:	usa@lasermet.com
Website:	www.lasermet.com